

A RESOLUTION ADOPTING THE GRID MANAGEMENT COMMITTEE'S RECOMMENDATIONS CLASSIFYING THE BATTERY ENERGY STORAGE SYSTEM AS A NEW SERVICES AND THE EXEMPTION THEREOF FROM THE CONDUCT ...

Read online (full-text search, related cases, audio case brief): <https://batas.org/library/eb67d3fa41ca/>

Adopted: 18 May 2015

Date Filed: 30 June 2015

WHEREAS, demand for electricity is a constant change inherent in all power systems. Thus, an unceasing need to maintain the balance between generation and load all the time as a pre requisite to a stable and reliable grid. The responsibility of balancing generation and load lies with the System Operator (SO) who is mandated by law to procure and arrange ancillary services sufficient to support the operation of the grid;

WHEREAS, the system frequency is the fundamental indicator of the real time condition of the power system as it provides an immediate indication of the balance between generation and load. Frequency drops when load exceeds generation and rises when generation exceeds load. Large frequency deviations result in equipment damage and power system collapse.[1] To avoid the latter scenario, adequate reserves suitable for various contingencies and/or disturbances are needed by the system and small, manageable frequency deviations must be corrected at the earliest opportunity;

WHEREAS, the frequency response performance of regulating reserve providers would spell a difference in the efficient operations of the system in times of frequency deviations. Fast response time is necessary for a more stable and reliable grid;

WHEREAS, the integration of renewable energy resources as a global advocacy, characterized by their intermittent nature, particularly wind and solar, may, to a certain degree, depending on the amount of penetration into the grid, cause significant degradation of system performance brought about by the variability of their output. An increase in variability requires a corresponding increase in ancillary service;

WHEREAS, advancements in technology continuously evolve, to address the ever changing universal issues and endless challenges in efficient power system operations. The Battery Energy Storage System (BESS) is a new technology that can provide Frequency Control Ancillary Services (FCAS), particularly, Contingency Reserve (Primary Reserve) and Frequency Regulation (Secondary Reserve);

WHEREAS, FCAS are those services required by the system operator to ensure supply and demand balancing in the power system. This requires precise control of system frequency through operational reserves that can respond to disturbances. FCAS are characterized differently in different electricity industry arrangements, depending upon the types of power system events they respond to, the timeframe over which they respond, the manner in which they are activated and whether they act to raise or lower the power system frequency;[2]

WHEREAS, the introduction of BESS as a new source of ancillary service for frequency control would be beneficial to the efficient operation of the grid, BESS has been in used by the system operators in most advanced and complex grid worldwide;

WHEREAS, after due deliberation, the GMC, at its regular meeting held on 12 March 2015, resolved to recommend to the ERC the BESS as a new source of frequency control ancillary services, particularly:

(1)

Contingency Reserve (primary reserve); and

(2)

Frequency Regulation (secondary reserve);

WHEREAS, the GMC further recommended the exemption of the BESS from the conduct of the System Impact Study (SIS), subject to the recommended siting and capacity for Luzon, Visayas, and Mindanao grids. Provided however, that the capacity of the BESS shall not, exceed the required frequency regulating (secondary) reserve in a particular location;

WHEREAS, the SIS is conducted for the purpose of determining whether or not the new element connected to the grid could cause an impact or degradation of the system performance.

According to the GMC, the purpose for which the SIS should be conducted is not much of a necessity under the present circumstances being that:

(1)

The power flow analysis which is conducted in order to ensure that thermal limits are not breached can be remedied by simply allocating the capacity that can be accommodated by the transmission line;

(2)

Batteries produce direct current, which flows only in one and same direction. Hence, the possible occurrence of short circuit is slim and has negligible impact to the grid; and

(3)

As to the dynamics, the BESS is static and will only be used for frequency regulation. Thus, it cannot cause instability to the grid;

WHEREAS, the exemption of BESS from the SIS is without prejudice to the required performance tests to be conducted by the NGCP, which shall certify the AS provider as qualified;

WHEREAS, to avoid confusion and to be consistent herewith, paragraphs 6.6.1.2 of the PGC Amendment No. 1 is hereby clarified to be interpreted in relation to or within the context of paragraphs 6.6.2.1 and 6.6.2.2 thereof. Thus -

“6.6.1.2. The Frequency Regulating (or Load following) Reserve shall include the following:

(a)

Primary Response of Generating Units; and

(b)

Secondary Response of Generating Units.”

“6.6.2.1 A generating Unit providing Primary Response for Frequency regulation as an Ancillary Service shall operate in an automatic Frequency- sensitive mode (also known as free-governor mode) for automatic response of the Unit's power output to changes in frequency. xxx”

“6.6.2.2 Secondary Response shall be required from selected Generating Units providing Ancillary Services for Frequency regulation. Frequency Control using the Secondary Response of the Generating Unit shall be accomplished through Automatic Generation Control or manual adjustment of generation with Specific Dispatch Instruction from the System Operator. xxx”

WHEREAS, at present, the firm contracted capacity for contingency reserve in Luzon is 340MW. The rest of the requirements are contracted on a non-firm basis. With BESS as an additional frequency ancillary service resource, the electricity that would be generated by the non-firm ancillary service providers would add up to the much needed power supply in the country thereby paving the way to a truly competitive power industry;

NOW THEREFORE, the ERC hereby RESOLVES to ADOPT the Grid Management Committee’s recommendations classifying the Battery Energy Storage System (BESS) as a new source of Frequency Control Ancillary Services (FCAS), particularly:

(1)

Contingency Reserve (primary reserve); and

(2)

Frequency Regulation (secondary reserve);

RESOLVED FURTHER, to exempt the BESS from the conduct of the System Impact Study (SIS), subject to the recommended siting and capacities for Luzon, Visayas, and Mindanao grids. Provided, however, that the capacity of the BESS shall not exceed the required frequency regulating reserve in a particular location. The exemption of BESS from the conduct of SIS is without prejudice to the required performance tests to be conducted by the NGCP, which shall certify the AS provider as qualified;

RESOLVED FINALLY, to clarify paragraphs 6.6.1.2 of the PGC Amendment No. 1 to be interpreted in relation to or within the context of paragraphs 6.6.2.1 and 6.6.2.2 thereof to avoid confusion.

“ 6.6.1.2 The Frequency Regulating (or Load following) Reserve shall include the following:

(a)

Primary Response of Generating Units; and

(b)

Secondary Response of Generating Units.”

“6.6.2.1 A generating Unit providing Primary Response for Frequency regulation as an Ancillary Service shall operate in an automatic Frequency- sensitive mode (also known as free-governor mode) for automatic response of the Unit’s power output to changes in frequency. xxx”

“6.6.2.2 Secondary Response shall be required from selected Generating Units providing Ancillary Services for Frequency regulation. Frequency Control using the Secondary Response of the Generating Unit shall be accomplished through Automatic Generation Control or manual adjustment of generation with Specific Dispatch Instruction from the System Operator. Xxx”

This Resolution shall take effect fifteen (15) days after its publication in a newspaper of general circulation.

Let copies of this Resolution be furnished the University of the Philippines Law Center - Office of the National Administrative Register (UPLC-ONAR), the Department of Energy (DOE), the National Transmission Corporation (TRANSCO), the National Grid Corporation of the Philippines (NGCP), the Philippine Electricity

Market Corporation (PEMC), and all the other parties concerned.

SO ORDERED.

Pasig City, May 18, 2015.

(SGD) ZENAIDA G. CRUZ-DUCUT

Chairperson

(SGD) ALFREDO J. NON

Commissioner

(SGD) GLORIA VICTORIA C. YAP-TARUC

Commissioner

(SGD) JOSEFINA PATRICIA A. MAGPALE-ASIRIT

Commissioner

[1] Cf. Ancillary Services: Technical and Commercial insights by Brendan Kirby 2007.

[2] Cf. Frequency Control Ancillary Services. Is Australia a Model Market for Renewable Integration? By Jenny Riesz, Iain MacGill, Center for Energy and Environmental Markets of NSW, Sydney, Australia.

ABOUT BATAS.ORG

Study smarter at BATAS.org

The Philippine bar review and law-school companion built around how your brain actually remembers.

The complete Philippine law library - free for everyone.

More than 100,000 Supreme Court decisions, Republic Acts, and executive issuances - full-text searchable, browsable by category and year, and always free. No paywall, no login. This PDF came from it.

Audio case-brief lectures.

Any decision becomes a podcast-style lecture - facts, issues, ruling, and doctrine - with read-along highlighting and a hands-free presentation mode. Study while commuting, working out, or resting your eyes.

Bar review built on the science of memory.

Complete, sequenced courses for all eight bar subjects, narrated like podcasts and reinforced with retrieval practice and spaced review - the study techniques with the strongest evidence behind them.

The full law-school curriculum.

One subscription unlocks the entire J.D. curriculum - every subject, every lesson, with your progress tracked down to the paragraph so you can pick up exactly where you left off, on any device.

Mock exams that tell you where you stand.

Timed multiple-choice exams graded instantly, with per-subject score breakdowns and focus suggestions that point you at your weakest topics first.

A study planner that keeps you on pace.

Set your schedule and BATAS tells you every day whether you are on track for bar day - and exactly which lesson to take next.

Start free at <https://batas.org>

The law library is free forever - and your first lesson is one click away.

The text of this document is an official public record and remains in the public domain. Formatting, presentation, and compilation © 2026 batas.org.

Downloaded free from the batas.org Law Library. Share it freely - the library is free for every law student, bar reviewee, and practitioner.